

Mesačný protokol emisného monitorovania z KM_(PK1,PK3e) za : 03.2019

Prevádzkovateľ: TEKO, a.s.

Meracie miesto: PK1, PK3e

Palivo		Zemný plyn			
ZL	PHH - 60min.	CO	NO _x	SO ₂	TZL
EL - Emisný limit	[mg/m ³ _{nr}]	100	100	35	5
I - interval spoľahlivosti	[%EL]	10	20	20	30
N PHH ≤ 2.EL+I / N PHH > 2.EL+I		0 / 0	0 / 0	0 / 0	0 / 0
N PHH Valid / N PHH N		0/744	0/744	0/744	0/744
N PDH < 1,1.EL+I / N PDH > 1,1.EL+I		0 / 0	0 / 0	0 / 0	0 / 0
N PDH Valid / N PDH F / N PDH N		0/0/31	0/0/31	0/0/31	0/0/31
c - priem. hm. koncent. (≤ EL)	[mg/m ³ _{nr}]	0,0	0,0	0,0	0,0
množstvo ZL (≤ EL)	[kg]	0,0	0,0	0,0	0,0
Q Spalin (≤ EL)	[tis. Nm ³]	0	0	0	0
c - priem. hm. koncent. (> EL)	[mg/m ³ _{nr}]	0,0	0,0	0,0	0,0
množstvo ZL (> EL)	[kg]	0,0	0,0	0,0	0,0
Q Spalin (> EL)	[tis. Nm ³]	0	0	0	0
množstvo ZL (N PDH F > 10, nezist. údaje)	[kg]	0,0	0,0	0,0	0,0
Q Spalin (N PDH F > 10, nezist. údaje)	[tis. Nm ³]	0	0	0	0

Počet hodín za mesiac - ustálený chod :		0 / 0				PDH - priemerné denné hodnoty [mg/m ³ _{nr}]					
Stav:	PK1 / PK3e					Zemný plyn					
	Bez	Ust	Náb	ZmQ	Odst	CO	NO _x	SO ₂	TZL		
Deň	-	""	N	Q	Z	(PK1,PK3e)	(PK1,PK3e)	(PK1,PK3e)	(PK1,PK3e)		
1-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
2-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
3-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
4-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
5-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
6-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
7-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
8-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
9-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
10-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
11-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
12-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
13-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
14-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
15-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
16-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
17-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
18-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
19-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
20-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
21-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
22-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
23-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
24-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
25-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
26-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
27-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
28-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
29-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
30-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
31-3-19	24 / 24	0 / 0	0 / 0	0 / 0	0 / 0	0,0	N	0,0	N	0,0	N
SUMA	744 / 744	0 / 0	0 / 0	0 / 0	0 / 0		N		N		N

Označenie PDH, PMH	
F	neplatná PDH (Počet platných PHH < 2/3 počtu PHH Ustálenej prevádzky)
N	nemeraná PDH (Počet PHH Ustálenej prevádzky = 0)
	platná PDH
G	PDH>1,1.EL+I (PMH>EL+I)

Dátum PDH > 1,1.EL + I	CO	NO _x	SO ₂	TZL
	x	x	x	x